



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Co.

Ref: ADDC/LVSGC/14/75

Date: 21/10/2014

To: M/s Eaton FZE
P.O. Box 261768,
Dubai, UAE
Tel No: 04-8066100
Fax No: 04-8894813

Subject: Eaton DBs & Panel Boards

Greetings,

We refer to your letter ref. UAE-0037-014 dated 21st October 2014 and the meeting held in ADWEA DG office on 29th September 2014 for the proposed LV materials. Please be informed that the proposed LV materials, as detailed below, is generally approved with the following conditions:

Sr. No	Product Reference	Max. Rating Cross section	Certificate No.	Manufacturer Country of Origin
1.	Eaton xBoard SPLIT TYPE-100A TPN, SPLIT BUSBAR MCB DISTRIBUTION BOARD (ISOLATO EATON)	100 A 1 x 12 x 5	ASTA 19317A	Abu Dhabi Switchgear Factory LLC ADSF/UAE
2.	Eaton Cutler Hammer 250A TPN MCCB Panel Board A series CA: MCCB, Eaton Cutler Hammer, USA, 3P	250 A 1 x 25 x 8	ASTA 17713A	
3.	Eaton Cutler Hammer 400A TPN MCCB Panel Board A series GA: MCCB, Eaton Cutler Hammer, USA, 3P	400 A 1 x 25 x 10	ASTA 17712A	
4.	Eaton Cutler Hammer 630A TPN MCCB Panel Board A series FA: MCCB, Eaton Cutler Hammer, USA, 3P	630 A 1 x 25 x 17	ASTA 17711A	



1. This approval is valid for **1 year** from the date of this letter
2. The above approval does not relieve the Contractors in complying with RSB guidelines and ADDC standards that are applied to the LV Switchgear and Panel Boards
3. All the breakers (both the incoming and outgoing) shall be restricted to the components used in the test or to be tested by any of the approved certified authorities
4. Submission of certificate of conformity for every switchgear assembly, at every delivery
5. Provision of the performance data of the switchgear from the owners of the installation for a period of 1 year
6. Any malfunction or repeated faults during this period may lead to the cancellation of the ADDC approval.
7. It is the responsibility of the manufacturer to comply with any updated IEC standards that would be released during these period by means of additional test as required.
8. It is the responsibility of the supplier to keep their customer aware of the special conditions stated in the test reports that restrict the use of the approved material at different connection environment.
9. The company should be registered in ADWEA (www.adwea.ae)
10. **This shall supersede earlier issued approvals reference:**
 - a. ADDC/LVSGC/14/0705091864 dated 24/2/2014
 - b. ADDC/LVSGC/TAH/1006030/13 dated 13/6/2013

Regards,



ENG. TARIQ ALI AL-HASHEMI

Chairman, Low Voltage Switchgear Committee (LVSGC)