



FIRE RESISTANT CABLES



FIRE RESISTANT CABLES

FP400

APPR OVALS

FP400 BS7846-F2







Prysmian FP400' is the original fire resistant armoured cable > providing an easy to install and terminate, robust fire resistant wiring system. In addition to maintaining circuit integrity during a fire, FP400[°] produces very low levels of smoke and virtually no (less than 0.5%) acidic gases, thus safeguarding human life and protecting equipment.

FP400' handles like a standard armoured cable and can be installed just as easily. No special tools or accessories are needed for installation or termination of FP400, which ensures that substantial installation cost savings, compared with MICC, can be achieved through its use.

FP400' is suitable for indoor or outdoor installation requiring a robust armoured cable, including direct burial, trough, fixed direct, tray or ladder.

Prysmian FP400° is BASEC approved to BS7846 Category F2. It is also Loss Prevention Certification Board (LPCB) listed as a fire resistant cable and approved to BS6387 Category CWZ, at an enhanced voltage of 600/1000V.

Witnessed project tests have demonstrated the ability of FP400" to achieve fire resistant properties in excess of those required by BS6387 Category CWZ and on the basis of these tests Prysmian FP400[°] has been approved for many projects where previously only MICC had been approved.

Additional tests have demonstrated the ability of FP400° to achieve a 60 minute rating (PH60) to BS EN50200 and a 30 minute rating to BS8434-1. These tests demonstrate that FP400 also meets the requirements for use in "standard" installations in accordance with BS5839-1:2002 for fire detection and alarm systems, and "Cables with inherently high resistance to attack by fire" in accordance with BS5266-1:2011 for emergency lighting.

All Prysmian FP400 cables are manufactured under an ISO 9001 Quality System certified by BASEC and LPCB.

Prysmian FP400' may be considered as a low smoke armoured cable to BS6724 for the purposes of installation and should be installed in accordance with BS7671/IEE Wiring Regulations or any other appropriate national regulations. Although standard armour cable fixings and glands may be used, it is important to ensure that, when the cable is required to maintain circuit integrity in a fire, any fixing used to support the cable can also withstand that fire. The use of the appropriate BICON gland or cleat is recommended.



FP 400

KEY APPLICATIONS

 Essential safety circuits associated with fire detection, fire alarm and emergency lighting. 	M Su ex
CABLE DESCRIPTION:	C/
CONDUCTOR Plain annealed copper stranded (class 2) conductor for ease of handling.	Sł Re Su
PRIMARY INSULATION Mineral ceramic (Mica/Glass) fire resistant tape	ot B
SECONDARY INSULATION	A
90°C cross - linked insulation	is
	ci
CORE IDENTIFICATION:	ha
HARMONISED CORE IDENTIFICATION:	А
o o brown-blue	N
 o o o brown-black-grey o o o o blue-brown-black-grey 	of
7-48 cores white with printed numbers	01
NON HARMONISED CORE IDENTIFICATION: o o red-black	St m
o o red-yellow-blue o o o o black-red-yellow-blue	W
Non harmonised colours to special order.	in
	SU
BEDDING Extruded LSOH bedding compound.	th
Extruded ESOT Bedding compound.	~
ARMOUR	C
Single layer of galvanised steel wires.	Tł
SHEATH	te Fo
SHEATH Robust LSOH sheath. Colour - black.	ar
Other colours to special order	ap

Rating factors for Amplent temperat	ures										
Ambient Temperature °C	25	30	35	40	45	50	55	60			
Rating factor	1.02	1.00	0.96	0.91	0.87	0.82	0.76	0.71			
Rating factors for grouping of cables											
Installation Method			Num	ber of circu	iits or multi-	core cables					
installation Method	2	3	4	5	6	7	8	9			

Number of circuits or multi-core cables											
9											
0.70											
0.90											
0.72											
-											

* Spaced by a clearance between adjacent surfaces of at least one cable diameter.

Where the horizontal clearance between adjacent cables exceeds 2 cable diameters no correction factor need be applied Note. Standard conditions of grouping as stated in BS7671 IEE Wiring Regs apply

. Range -25 to +90°C

Shaped conductor r=8D

BSEN60332-3-24

PRYSMIAN

FIRE RESISTANT CABLES

INSTALLATION

linimum recommended installation temperature 0°C. uitable for indoor and outdoor installations. For external exposure the use of a Black sheath is recommended.

Should be installed in accordance with BS7671/IEE Wiring egulations or any other appropriate national regulations.

uitable for direct burial, trough, tray, ladder or ther installations requiring a robust armoured cable.

SENDING RADIUS

minimum internal radius of bend of 6 x cable diameter recommended during installations for cables having ircular conductors and 8 x cable diameter for cables aving shaped conductors.

CCESSORIES

lo special accessories are required for the installation of FP400[°].

tandard brass armoured cable glands and cast iron cleats hay be used.

Vhen the cable is required to maintain circuit integrity n a fire, it is important that any accessory used to upport the cable can also withstand that fire. The use of he appropriate BICON[®] gland or cleat is recommended.

CURRENT RATINGS

The tabulated ratings are based upon a 30°C ambient

emperature and a 90°C operating temperature.

or other ambient temperatures or where cables

re grouped together, the following rating factors should be applied.



Nominal cross sectional area	Approximate overall diameter	Approximate diameter under armour	Nominal diameter of armour wires	Approximate cable weight	Maximum conductor resistance at 20°C	rating (1 sec) of conductor	Current rating Three phase AC Clipped direct	Three phase AC Free Air	Volt drop Three phase AC	Nominal cross sectional area	Approximate overall diameter	Approximate diameter under armour	Nominal diameter of armour wires	Approximate cable weight	Maximum conductor resistance at 20°C	Current rating DC or Single phase AC Clipped direct	Current rating DC or Single phase AC Free Air	Volt drop DC	Volt drop Single phase AC
mm²	mm	mm	mm	kg/km	ohms/km	KA	Amps	Amps	mV/A/m	mm²	mm	mm	mm	kg/km	ohms/km	Amps	Amps	mV/A/m	mV/A/m
Three Core												Two	Core						
1.5	13.4	8.8	0.9	340	12.1	0.20	23	25	27	1.5	12.9	8.3	0.9	310	12.1	27	29	31	31
2.5	14.8	10.2	0.9	430	7.41	0.35	31	33	16	2.5	14.1	9.6	0.9	380	7.41	36	39	19	19
4	16.1	11.5	0.9	510	4.61	0.57	42	44	10	4	15.2	10.6	0.9	450	4.61	49	52	12	12
6	17.4	12.8	0.9	620	3.08	086	53	EG	6.8	6	16.4	12.0	0.9	530	3.08	62	66	7.9	7.9
0	17.4	12.8	0.9	620	5.08	080	22	56	0.8	10	18.6	14.0	0.9	630	1.83	85	90	4.7	4.7
10	20.3	14.8	1.25	930	1.83	1.4	73	78	4.0	16	21.4	15.9	0.9	920	1.15	110	115	2.9	2.9
16	22.8	17.1	1.25	1210	1.15	2.2	94	99	2.5	25	23.7	18.3	1.25	1200	0.727	146	152	1.85	1.9
25	27.4	20.8	1.6	1800	0.727	3.6	124	131	1.65	35	27.2	20.9	1.6	1600	0.524	180	188	1.35	1.35
35	29.2	22.4	1.6	2100	0.524	5.0	154	162	1.15	50	28.0	21.2	1.6	2000	0.387	219	228	0.98	1.00
50	33.0	26.2	1.6	2600	0.387	7.1	187	197	0.87	70	30.7	23.7	1.6	2400	0.268	279	291	0.67	0.69
70	37.0	30.0	1.6	3400	0.268	10.0	238	251	0.60	95	35.3	27.3	2.0	3300	0.193	338	354	0.49	0.52
95	40.6	32.4	2.0	4500	0.193	13.6	289	304	0.45	120	36.6	28.4	2.0	3800	0.153	392	410	0.39	0.42
120	43.8	35.4	2.0	5500	0.153	17.2	335	353	0.37	150	39.3	30.9	2.0	4400	0.124	451	472	0.31	0.35
150	48.0	38.4	2.5	6900	0.124	21.4	386	406	0.30	185	44.2	34.4	2.5	5700	0.0991	515	539	0.25	0.29
185	52.0	42.2	2.5	8200	0.0991	26.5	441	463	0.26	240	48.0	38.0	2.5	7200	0.0754	607	636	0.195	0.24
240	57.1	46.9	2.5	10200	0.0754	34.3	520	546	0.21	300	51.8	41.6	2.5	8300	0.0601	698	732	0.155	0.21
300	63.0	52.6	2.5	12200	0.0601	42.9	599	628	0.185	400	55.9	45.3	2.5	10500	0.0470	787	847	0.120	0.19
400	69.5	58.7	2.5	15000	0.0470	57.2	673	728	0.165					Sever	Core				
				Four	r Core					1.5	16.4	11.8	0.9	500	12.1	27 *	29*	31	31
1.5	14.3	9.7	0.9	390	12.1	0.20	23	25	27	2.5	18.3	13.7	0.9	640	7.41	36 *	39*	19	19
2.5	16.0	11.4	0.9	490	7.41	0.35	31	33	16	4	20.8	15.3	1.25	910	4.61	49*	52*	12	12
4	17.3	12.7	0.9	590	4.61	0.57	42	44	10					Twelve	e Core				
6	19.6	14.1	1.25	830	3.08	0.86	53	56	6.8	1.5	21.2	15.7	1.25	850	12.1	27 *	29*	31	31
10	21.8	16.3	1.25	1040	1.83	1.4	73	78	4.0	2.5	24.0	18.3	1.25	1090	7.41	36*	39*	19	19
16	24.6	18.9	1.25	1370	1.15	2.2	94	99	2.5	4	27.3	20.9	1.6	1550	4.61	49*	52*	12	12
25	29.1	22.5	1.6	2100	0.727	3.6	124	131	1.65					Ninetee	en Core				
35	32.2	25.4	1.6	2500	0.524	5.0	154	162	1.15	1.5	24.2	18.5	1.25	1120	12.1	27 *	29*	31	31
50	35.0	28.0	1.6	3200	0.387	7.1	187	197	0.87	2.5	28.6	22.0	1.6	1650	7.41	36 *	39*	19	19
70	40.2	32.0	2.0	4500	0.268	10.0	238	251	0.60					Twenty-se	even Core				
95	44.0	35.6	2.0	5600	0.193	13.6	289	304	0.45	1.5	29.4	22.8	1.6	1650	12.1	27 *	29*	31	31
120 150	48.4 52.5	38.8 42.7	2.5 2.5	7200 8500	0.153 0.124	17.2 21.4	335 386	353 406	0.37 0.30	2.5	33.4	26.6	1.6	2150	7.41	36 *	39*	19	19
185	52.5	42.7	2.5	10300	0.124	21.4	380 441	406	0.30					Thirty-se	ven Core				
240	62.7	52.3	2.5	12800	0.0754	34.3	520	403 546	0.20	1.5	32.2	25.6	1.6	2000	12.1	27 *	29*	31	31
300	69.6	58.8	2.5	12800	0.0601	42.9	599	628	0.21	2.5	36.7	29.9	1.6	2650	7.41	36 *	39*	19	19
400	78.0	65.3	3.15	20400	0.0470	57.2	673	728	0.165										
400	78.0	65.3	3.15	20400	0.0470	57.2	6/3	728	0.165										

Circular conductor 1.5 - 35mm² Shaped conductor 50mm² and above. Installation methods for current rating in accordance with BS7671/IEE Wiring Regulations. The tabulated ratings are based upon a 30°C ambient temperature and 90°C operating temperature.

*The tabulated rating is as a two core cable and may be used where the number of cores carrying current does not exceed its square root of the total number of cores.



LOW VOLTAGE 600/1000V





023 8029 5465

Tel: +44 23 8029 5481





Should you have any concerns about unsafe, non-approved or counterfeit cable, please contact the ACI

Tel: 0208466979 Email: report@aci.org.uk

SCAN THIS TO ACCESS www.afumexcables.co.uk IN THREE SIMPLE STEPS.

- Download any QR reader or barcode app for your smartphone.
 Scan the QR code on the left with your phone.